

Condensing Boiler Equipment  
 Bid # 17-28  
 RESULTS

**BOARD APPROVED**

FW Webb,  
 North  
 Brunswick, NJ

Unitemp,  
 Somerset, NJ

ITEM	DESCRIPTION	QTY	UNIT	UNIT PRICE	TOTAL PRICE	UNIT PRICE	TOTAL PRICE
1	Aerco Benchmark Series Boiler Model BMK-1000 or equal to include the following: Burner capable of 20 to 1 turndown ratio, Fully condensing design with up to 98% efficiency, 439 Stainless steel heat exchanger, Full modulation of gas train (boiler input range 1,000 MBH down to 50 MBH with infinite points in between, Fire tube boiler, Oxygen level monitoring system (factory installed), Electric type low water level cutoff with test (factory installed), Manual reset and dual over-temperature protection (factory installed), Remote fault alarm contacts, Condensate neutralization tube (1 per boiler), No water flow switch required on Aerco boilers, Ten (10) year warranty (non-prorated) on pressure vessel and heat exchanger against leakage due to condensate corrosion, mechanical stress failure, mechanical defects on workmanship, Provide factory furnished pressure relief valve, provide factory furnished boiler control, control panel shall be compatible with LONWORKS controls, provide a condensate neutralizer kit, provide an outdoor temperature sensor. Two (2) year warranty on the C-MORE control panel, 18 Months on all other components, ACS boiler control panel, Condensate neutralizer, one per boiler, Supervision of startup and owners training. See boiler schedule attached.	2	ea	\$ 15,767.20	\$ 31,534.40	\$ 30,533.00	\$ 61,066.00